



CITY OF
FORESTPARK

CITY OF FOREST PARK, GEORGIA

STARR PARK - PHASE I

PROJECT NO.: 02072023

ADDENDUM NO. 3

APRIL 3, 2023

ALL BIDDERS FOR THE REFERENCED PROJECT ARE REQUIRED TO MAKE THE CHANGES BELOW TO THE EXISTING CONTRACT DOCUMENTS OBTAINED FROM THE CITY OF FOREST PARK'S WEBSITE FOR BIDDING PURPOSES:

ITEM NO. 1: RESPONSE TO ADDITIONAL WRITTEN QUESTIONS RECEIVED:

- **QUESTION:**
 - How many type "F Buildings are there?
- **RESPONSE:**
 - There are 2 type F pavilions.

- **QUESTION:**
 - Is a Fire Alarm System required for any of the buildings?
- **RESPONSE:**
 - No, none of the buildings require a Fire Alarm System.

- **QUESTION:**
 - The drawing E-001 do have a legion for the Fire Alarm System.
- **RESPONSE:**
 - None of the buildings required a Fire Alarm System. Sheet E-001 states that not all items listed on the legend are used on the plans.

- **QUESTION:**
 - There should be a requirement for fire alarm protection by code.
- **RESPONSE:**
 - None of the buildings required a Fire Alarm System. Sheet E-001 states that not all items listed on the legend are used on the plans.
- **QUESTION:**
 - PSC (Presentation System Contractor) is shown in the abbreviation section. Who is the PSC contact person and contact number?
- **RESPONSE:**
 - None of the buildings required a Fire Alarm System. Sheet E-001 states that not all items listed on the legend are used on the plans.
- **QUESTION:**
 - PSC (Presentation System Contractor) is shown in the abbreviation section. Who is the PSC contact person and contact number?
- **RESPONSE:**
 - None of the buildings required a Fire Alarm System. Sheet E-001 states that not all items listed on the legend are used on the plans.
- **QUESTION:**
 - The 'Artificial Grass field Turf' specifications in item 3.4 'Field Markings' talk about markings being inlaid/painted. Are all of these markings inlaid, or painted? Those same specifications also specify markings for a football field, and they also specify a logo. Are there any other field detail layouts that would show the markings, logo, and color detail specifics? All I see in the plan layouts is one soccer field not showing any field marking or logo information anywhere.
- **RESPONSE:**
 - No logo is required. Please ignore references to logo. Striping for one soccer field will be inlaid. Exact dimensions of field striping shall be coordinated with Site Designer and Owner.
- **QUESTION:**
 - The specifications for 'Artificial Grass field Turf' are specifying turf for football and soccer fields, and also for baseball and softball fields. The plan layouts only show one soccer field of 46,000 SF, and the item list only has 1 synthetic turf item with this quantity of 46,000 SF. Why are baseball and softball fields being specified? Are there any baseball and softball fields elsewhere that are required, or is this for upcoming projects?
- **RESPONSE:**
 - For current phase, there will only be a multipurpose football / soccer field. Please ignore references to baseball and softball fields for this project.

END OF ADDENDUM NO. 3

Where any original item, term or requirement is not specifically amended, voided or superseded by this addendum, it will remain in effect. This clarification is being provided to all known respondents.

This Addendum must be completed, signed, and attached to the RFP to acknowledge receipt of Addendum. **FAILURE TO ACKNOWLEDGE THIS ADDENDUM MAY RESULT IN REJECTION OF PROPOSAL.**

Business Name _____

Authorized Signature _____ Date _____

Typed Name

& Title _____