



**City of Forest Park**  
**Department of Planning and Community Development**

785 Forest Parkway Forest Park, GA 30297 404-366-4720 www.forestparkga.gov

**Residential Rental Inspection Program**  
**Self-Inspection Checklist**



**Owner Information** (Please print legibly)

First Name:	Last Name:	OWN ID:
-------------	------------	---------

**Property Address** (Please use one form per address / unit)

Street Address:	Unit #:
-----------------	---------

Item #	Part I: Exterior Inspection	Pass	Fail	N/A	Comments
1.1	<b>Legible and Visible Address Number and Unit Identification</b> (Address numbers clearly visible from street/number or letters for units- minimum 4 in high, if new)				
1.2	<b>Roof</b> (Must be free from any visible holes or penetrations that allows outside elements - rain & cold - in and heated air out.)				
1.3	<b>Storage of Junk and Rubbish and/or Overgrown Vegetation</b> (Household trash, tires, scrap wood, scrap metal, etc. shall be stored and protected in an orderly fashion as to not be an attractive nuisance – Property must be clear from any overgrown/dry vegetation and/or weeds capable of being ignited and endangering the property)				
1.4	<b>Dumpsters/Trash Cans</b> (Must be in enclosure if provided/stored out of public right-of-way/ free from trash overflow)				
1.5	<b>Inoperable/Unregistered Vehicles</b> (Inoperable vehicles must be stored out of the front yard or exterior side yard and on a paved surface)				
1.6	<b>Foundation Vent Screens/Crawl Space Covers</b> (Spaces must be properly covered. Screens must be in good working condition)				
1.7	<b>Stairways – Landings/Treads/Risers/Balusters</b> (Should be in good condition/free from visible structural defects (loose threads, missing balusters or handrails, rotting or deteriorating materials) and anything that could cause a trip or fall hazard.)				
1.8	<b>Exterior Walkways/Exit Passageways/Common Areas</b> (Must remain clear at all times and in a safe and sanitary condition)				
1.9	<b>Exterior Lighting</b> (Approved lighting fixtures at entrance/exiting doors, all exterior hallways, as applicable)				
1.10	<b>Electrical Panel</b> (Must have a panel cover and breakers labeled with appropriate identification, as applicable)				
1.11	<b>Water Heaters</b> (Must have proper strapping, proper drain lines, and venting)				
1.12	<b>Exterior Surfaces</b> (Surfaces shall be protected by painting or other protective covering from the elements)				
1.13	<b>Infestation</b> (Property must be clear of all infestations - insect, rodent, etc.)				
<b>For Multi Family (3+ units) Only</b>					
1.14	<b>Fire Extinguishers</b> (Must be properly serviced, labeled, and stored – minimum size 2A10-BC)				
1.15	<b>Fire Sprinkler System</b> (If provided – Certification of 5 year inspection required )				
1.16	<b>Electrical/Gas Meters</b> (Must have proper labeling, be properly protected, and must not be tampered with. Utilities in an exterior closet or room may require signage)				
1.17	<b>Existing Fire Lanes Clearly Marked</b> (Signage or paint or both needed)				

I certify and declare under penalty of perjury that I have inspected the aforementioned unit and the information above is true and correct to the best of my knowledge.

Name (Please print): \_\_\_\_\_ Relationship to Property: \_\_\_\_\_

Phone Number: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_



City of Forest Park

Department of Planning and Community Development

Residential Rental Inspection Program  
Self-Inspection Checklist



785 Forest Parkway Forest Park, GA 30297 404-366-4720 www.forestparkga.gov

Owner Information (Please print legibly)					
First Name:		Last Name:		OWN ID:	
Property Address (Please use one form per address / unit)					
Street Address:					Unit #:
Item #	Part II: Interior Inspection	Pass	Fail	N/A	Comments
2.1	<b>Hot/Cold Running Water</b> (Unit must have hot and cold running water)				
2.2	<b>Electrical Power</b> (Unit must have electrical power)				
2.3	<b>Heat</b> (Unit must have a functioning adequate heating source – This excludes portable heating units)				
2.4	<b>Sewage System</b> (Unit must have a functioning sewage system and must be clear of any surfacing sewage indoors or outdoors)				
2.5	<b>Entry Doors</b> (Must be in good condition – Locks on doors must not exceed 48" in height, unless otherwise allowed. No double key lock on entry door)				
2.6	<b>Exits</b> (One main door per unit & escape/rescue window per bedroom. There must not be any double key locks on any exit doors throughout the unit)				
2.7	<b>Infestation</b> (Unit must be clear of any infestations – insect, rodent, etc.)				
2.8	<b>Smoke Alarms</b> (Must be working, in good condition and properly installed in each room used for sleeping, hallways leading to rooms used for sleeping, and in all levels including basements.)				
2.9	<b>Mechanical</b> (All mechanical equipment in the unit must properly function including; appliances, venting systems, thermostats, air conditioning unit – if provided, etc.)				
2.10	<b>Electrical and Electrical Sub Panel</b> (All wiring and electrical components must be in good working condition – no spliced wiring, no exposed wiring, and all outlets and switch plates must have appropriate coverings/GFCI in bath and kitchen operational, if applicable. All breakers in the sub-panel must be properly labeled and identified, no open slots or exposed wires.)				
2.11	<b>Plumbing</b> (Unit must have proper plumbing throughout unit – sink, toilet, bathtub or shower, no leaks, must have P-traps, toilets must be secured to ground and sinks must be secured to walls, etc.)				
2.12	<b>Food Prep Area</b> (Are required in kitchens – sink and counter)				
2.13	<b>Windows</b> (All windows must have adequate weather protection – no broken glass/plastic coverings, etc. - be in good condition and have locking mechanisms that function without use of key or special knowledge. If window bars or screens are present they too must function without use of key or special knowledge.)				
2.14	<b>Flooring</b> (Floors must not be in a defective or deteriorating condition that could cause a trip or fall hazard or impact sub-flooring)				
2.15	<b>Sub-flooring</b> (Must be in good condition without buckling or sagging which suggests structural defects)				
2.16	<b>Walls</b> (Must be good habitable condition clear of large holes, missing sections, etc.)				
2.17	<b>Ceiling</b> (Must be in good repair, must not be collapsing, buckling or sagging suggesting structural defects or roof leakage)				